



2019/20 REPORT FOR TESTING LEAD CONTENT IN DRINKING WATER OF SCHOOL FACILITIES

School District Information		Health Authority (HA) Information	
SD No.	84	Region	Vancouver Island North
SD Name	Vancouver Island West	Contact Name	
SD Contact Name:	Deane Johnson	Contact Phone	
SD Contact Phone:	250-504-0614	Report Submitted to HA	
Report Date	02-Jun-20	Report Submission Date	

[Click here to access the School Master List for Facility Names and Facility Codes](#)

SCHOOL FACILITY INFORMATION				TEST INFORMATION					MITIGATION STRATEGY & PUBLIC COMMUNICATION PLAN			ADDITIONAL INFORMATION		
School District Number	Ministry Facility Code	School Facility Name	Year Built	Date of Test (mm/yyyy)	Total Samples	Water Fixture Type	Room Location	Lead Level Result (mg/L)	Exceed Maximum Acceptable Concentrations	Mitigation Strategy Description	Describe Public Communication Plan	Comments	Next Scheduled Date of Testing (mm/yyyy)	Ministry Submission Period
84	8484041	Zeballos Elementary School	2013	03/2020	2	Sink	Staff Room	0.000	No				03/2023	30-Mar-20
84	8484041	Zeballos Elementary School	2013	03/2020	2	Sink	Staff Room	0.000	No				03/2023	30-Mar-20
84	8484041	Zeballos Elementary School	2013	03/2020	2	Tap	Kitchen	0.001	No				03/2023	30-Mar-20
84	8484041	Zeballos Elementary School	2013	03/2020	2	Tap	Kitchen	0.001	No				03/2023	30-Mar-20
84	8484041	Zeballos Elementary School	2013	03/2020	2	Water Fountain	Primary Room	0.002	No				03/2023	30-Mar-20
84	8484041	Zeballos Elementary School	2013	03/2020	2	Water Fountain	Primary Room	0.002	No				03/2023	30-Mar-20
84	8484041	Zeballos Elementary School	2013	03/2020	2	Water Fountain	Hallway	0.000	No				03/2023	30-Mar-20
84	8484041	Zeballos Elementary School	2013	03/2020	2	Water Fountain	Hallway	0.000	No				03/2023	30-Mar-20
84	8484012	Gold River Secondary	1967	03/2020	2	Water Fountain	Hallway	0.000	No				03/2023	30-Mar-20
84	8484012	Gold River Secondary	1967	03/2020	2	Sink	Staff Room	0.001	No				03/2023	30-Mar-20
84	8484012	Gold River Secondary	1967	03/2020	2	Sink	Staff Room	0.001	No				03/2023	30-Mar-20
84	8484012	Gold River Secondary	1967	03/2020	2	Sink	Foods Room 1	0.002	No				03/2023	30-Mar-20
84	8484012	Gold River Secondary	1967	03/2020	2	Sink	Foods Room 1	0.002	No				03/2023	30-Mar-20
84	8484012	Gold River Secondary	1967	03/2020	2	Sink	Foods Room 2	0.002	No				03/2023	30-Mar-20
84	8484012	Gold River Secondary	1967	03/2020	2	Sink	Foods Room 2	0.002	No				03/2023	30-Mar-20
84	8484012	Gold River Secondary	1967	03/2020	2	Water Fountain	Hallway	0.000	No				03/2023	30-Mar-20
84	8484011	Ray Watkins Elementary	2007	03/2020	2	Water Fountain	Hallway	0.001	No				03/2023	30-Mar-20
84	8484011	Ray Watkins Elementary	2007	03/2020	2	Sink	Staff Room	0.000	No				03/2023	30-Mar-20
84	8484011	Ray Watkins Elementary	2007	03/2020	2	Sink	Staff Room	0.000	No				03/2023	30-Mar-20
84	8484011	Ray Watkins Elementary	2007	03/2020	2	Sink	Multi Purpose Primary	0.001	No				03/2023	30-Mar-20
84	8484011	Ray Watkins Elementary	2007	03/2020	2	Sink	Multi Purpose Primary	0.001	No				03/2023	30-Mar-20
84	8484011	Ray Watkins Elementary	2007	03/2020	2	Sink	Multi Purpose Inter	0.001	No				03/2023	30-Mar-20
84	8484011	Ray Watkins Elementary	2007	03/2020	2	Sink	Multi Purpose Inter	0.000	No				03/2023	30-Mar-20
84	8484011	Ray Watkins Elementary	2007	03/2020	2	Water Fountain	Hallway	0.000	No				03/2023	30-Mar-20
84	8484011	Ray Watkins Elementary	2007	03/2020	2	Water Fountain	Hallway	0.000	No				03/2023	30-Mar-20
84	8484011	Ray Watkins Elementary	2007	03/2020	2	Water Fountain	Primary 1	0.001	No				03/2023	30-Mar-20
84	8484011	Ray Watkins Elementary	2007	03/2020	2	Water Fountain	Primary 1	0.001	No				03/2023	30-Mar-20
84	8484011	Ray Watkins Elementary	2007	03/2020	2	Water Fountain	Primary 2	0.000	No				03/2023	30-Mar-20
84	8484011	Ray Watkins Elementary	2007	03/2020	2	Water Fountain	Primary 2	0.000	No				03/2023	30-Mar-20
84	8484011	Ray Watkins Elementary	2007	03/2020	2	Water Fountain	Primary 3	0.001	No				03/2023	30-Mar-20
84	8484011	Ray Watkins Elementary	2007	03/2020	2	Water Fountain	Primary 3	0.001	No				03/2023	30-Mar-20
84	8484011	Ray Watkins Elementary	2007	03/2020	2	Water Fountain	Intermediate 1	0.000	No				03/2023	30-Mar-20
84	8484011	Ray Watkins Elementary	2007	03/2020	2	Water Fountain	Intermediate 1	0.000	No				03/2023	30-Mar-20
84	8484022	Captain Meares Elem/Sec	1972	03/2020	2	Sink	Staff Room	0.001	No				03/2023	30-Mar-20
84	8484022	Captain Meares Elem/Sec	1972	03/2020	2	Sink	Staff Room	0.000	No				03/2023	30-Mar-20
84	8484022	Captain Meares Elem/Sec	1972	03/2020	2	Sink	Foods Room 1	0.005	No		Close to Max, Flush Daily		03/2023	30-Mar-20
84	8484022	Captain Meares Elem/Sec	1972	03/2020	2	Sink	Foods Room 1	0.005	No		Close to Max, Flush Daily		03/2023	30-Mar-20
84	8484022	Captain Meares Elem/Sec	1972	03/2020	2	Sink	Foods Room 2	0.003	No				03/2023	30-Mar-20
84	8484022	Captain Meares Elem/Sec	1972	03/2020	2	Sink	Foods Room 2	0.002	No				03/2023	30-Mar-20
84	8484022	Captain Meares Elem/Sec	1972	03/2020	2	Water Fountain	Hallway	0.001	No				03/2023	30-Mar-20
84	8484022	Captain Meares Elem/Sec	1972	03/2020	2	Water Fountain	Hallway	0.001	No				03/2023	30-Mar-20
84	8484041	Kyuquot Elem/Sec	1986	03/2020	2	Water Fountain	Hallway	0.001	No				03/2023	30-Mar-20
84	8484041	Kyuquot Elem/Sec	1986	03/2020	2	Water Fountain	Hallway	0.001	No				03/2023	30-Mar-20
84	8484041	Kyuquot Elem/Sec	1986	03/2020	2	Sink	Staff Room	0.001	No				03/2023	30-Mar-20
84	8484041	Kyuquot Elem/Sec	1986	03/2020	2	Sink	Staff Room	0.001	No				03/2023	30-Mar-20
84	8484041	Kyuquot Elem/Sec	1986	03/2020	2	Water Fountain	Primary	0.003	No				03/2023	30-Mar-20
84	8484041	Kyuquot Elem/Sec	1986	03/2020	2	Water Fountain	Primary	0.002	No				03/2023	30-Mar-20
84	8484041	Kyuquot Elem/Sec	1986	03/2020	2	Water Fountain	Secondary	0.001	No				03/2023	30-Mar-20
84	8484041	Kyuquot Elem/Sec	1986	03/2020	2	Water Fountain	Secondary	0.001	No				03/2023	30-Mar-20
84	8484041	Kyuquot Elem/Sec	1986	03/2020	2	Water Fountain	Intermediate	0.001	No				03/2023	30-Mar-20
84	8484041	Kyuquot Elem/Sec	1986	03/2020	2	Water Fountain	Intermediate	0.001	No				03/2023	30-Mar-20
84	8484041	Kyuquot Elem/Sec	1986	03/2020	2				-					30-Mar-20
84									-					30-Mar-20
84									-					30-Mar-20
84									-					30-Mar-20
84									-					30-Mar-20
84									-					30-Mar-20
84									-					30-Mar-20
84									-					30-Mar-20
84									-					30-Mar-20
84									-					30-Mar-20
84									-					30-Mar-20